



Germaniastraße 28 Postfach 700110  
44379 Dortmund 44371 Dortmund  
Telefon: (0231) 61009-0 Fax: (0231) 61009-80

**FDA-Eignung, Serie:**  
**FDA-Suitability, series:**  
**RF**

Hiermit bestätigen wir, dass Rückschlagventile und Dichtungssätze der Serien RF mit den nachfolgenden Dichtungen und Packungen für den Lebensmitteleinsatz geeignet sind.

*We hereby confirm, that the non-return valves and sealing kits of series RF with the following sealings and packings are intended to come into contact with food*

| <b>Bauteil<br/>Part</b> | <b>Material<br/>Material</b> | <b>Zulassung<br/>Approval</b> |
|-------------------------|------------------------------|-------------------------------|
| Sitzring / Seat         | EPDM                         | FDA 21 CFR §177.2600          |
|                         | FEP/FPM                      | FDA 21 CFR §177.1550          |

Vor der Montage von Armaturen oder Ersatzteilen müssen diese gründlich gereinigt werden. Bei der Handhabung und der Montage von Ersatzteilen ist darauf zu achten, dass diese nicht durch Fremdstoffe bleibend verunreinigt werden und das spätere Produkt durch Kontamination gefährdet wird. Die Armaturen und die Rohrleitungen müssen nach der Montage entsprechend gereinigt werden, um eine bleibende Kontamination zu vermeiden.

*Before installation, valves or spare parts have to be cleaned thoroughly.  
During handling and installation of spare parts, it is necessary to take care to avoid a contamination of them and transferring outside contaminants to the product.  
Valves and pipeline must be cleaned after installation and prior to use, in order to avoid contaminations.*

Dortmund, 09.03.2021

  
(i. V. B. Ploeger, QMB)