


## EU - Type Examination Certificate


- (1)
- (2) Equipment and protective systems intended for use in potentially explosive atmospheres – **Directive 2014/34/EU**
- (3) EU - Type Examination Certificate Number
- EPS 16 ATEX 1 012 X** **Revision 2**
- (4) Equipment: limit switch box
- Type: EFX...ED... / EFE...ED..., EFX...EIA... / EFE...EIA..., EFX...IA... / EFE...IA...  
and EFX...K2D... / EFE...K2D...
- (5) Manufacturer: EUROTEC Antriebszubehör GmbH
- (6) Address: Bildstock 37  
88085 Langenargen  
Germany
- (7) This equipment and any acceptable variation thereto are specified in the annex to this certificate and the documentation therein referred to.
- (8) Bureau Veritas Consumer Products Services Germany GmbH, notified body No. 2004 in accordance with Article 21 given in the Directive 2014/34/EU of the European Parliament and of the Council of 26 February 2014, certifies that this equipment has been found to comply with the essential health and safety requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II of the Directive. The examination and test results are recorded in the confidential documentation under the reference number 16TH0022.
- (9) Compliance with the essential health and safety requirements has been assured by compliance with:
- EN 60079-0:2012 + A11:2013      EN 60079-1:2014      EN 60079-31:2014**  
**EN 60079-7:2015                      EN 60079-11:2012**
- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the annex to this certificate.
- (11) This EU - Type Examination Certificate relates only to the design and construction of the specified equipment in accordance with Directive 2014/34/EU. Further requirements of this Directive apply to the manufacture of this equipment and its placing on the market. Those requirements are not covered by this certificate.


**EU - Type Examination Certificate EPS 16 ATEX 1 012 X**

**Revision 2**

(12) The marking of the equipment shall include the following:

EFX...ED... II 2G Ex db eb IIC T4 - T6 Gb  
EFE...ED...  II 2D Ex tb IIIC T80°C - T135°C Db

EFX... EIA... II 2G Ex eb ia IIC T4 - T6 Gb  
EFE... EIA...  II 2D Ex tb IIIC T80°C - T135°C Db

EFX...IA... II 2G Ex ia IIC/IIB T4 - T6 Gb  
EFE...IA...  II 2D Ex ia IIIC T80°C - T135°C Db

EFX...K2D... II 2D Ex tb IIIC T80°C - T135°C Db  
EFE...K2D...: 



Certification department of explosion protection

Hamburg, 2021-02-22

H. Schaffer





(13)

## Annex

(14) **EU - Type Examination Certificate EPS 16 ATEX 1 012 X**

Revision 2

(15) Description of equipment:

The limit switch boxes are used for feedback and control of the position of valves, which are actuated by pneumatic actuators. The shaft of the limit switch is connected to the shaft of the rotary actuator and is rotated in the rotational movement of the rotary actuator. The fixed to the shaft switching cams actuate thereby the built-in sensors, which are used for electric signal transduction. The limit switch boxes fulfill the IP rating of IP66/67.

For the use to a minimum ambient temperature of -25°C the limit switch boxes type EFX can also be fitted with a viewing glass in the cover housing.

### Viewing Glass:

2D	flat
3D	dome
3D1	dome with OPEN-CLOSE indicator
OS	without viewing glass

The flex Ex de tb limit switch boxes type EFX...ED... / EFE...ED... are, depending on the model, equipped with 1 to 3 mechanical Ex-d switches and also serve as ex-e terminal compartment for carrying a maximum of two electrical signals.

The flex Ex ia limit switch boxes type EFX...IA... / EFE...IA... are, depending on the model, equipped with 1 to 4 mechanical micro switches or separately certified intrinsically safe sensors. These include 1 to 4 inductive V3-sensors, 1 to 4 proximity switches, 1 to 2 cylindrical sensors or 1 double sensor. Additionally the device serves as a connection box for up to two intrinsic safe circuits which can be fed through.

The flex Ex eb ia limit switch boxes type EFX...EIA... / EFE...EIA... are, depending on the model, equipped with 1 to 4 mechanical micro switches or separately certified intrinsically safe sensors, analog to the type EFX...IA / EFE...IA.... They also serve as ex-e terminal compartments for carrying a maximum of two electrical signals.

The flex Ex tb limit switch boxes type EFX...K2D... / EFE...K2D... are intended for dust hazardous areas and can be equipped with different switch combinations. As for the type EFX...ED... / EFE...ED..., electrical signals can be fed through the box type EFX...K2D... / EFE...K2D... which thus serves as a connection box. The maximum allowed internally dissipated power, see section (17), shall never be exceeded.

The limit switch boxes type EFX are permitted to be equipped with a shaft feedthrough in the cover, which is from the same construction as above. By this another possibility occurs for an interface according to VDI/VDE3845. This construction then allows the connection of further components.



**EU - Type Examination Certificate EPS 16 ATEX 1 012 X**

**Revision 2**

Electrical data:

Uo: 8,2V DC

Ui: 30V, li: 25mA, Pi: 34mW, Ci: 40nF, Li: 50µH

EFX...ED... The electrical data depends on the according switch types and can be taken from the according datasheet or the user manual.

EFE...ED...

Electrical fed through circuits:  
minimum cross section size 0.5 mm<sup>2</sup>, maximum current 6 A

EFX...IA... The electrical data depends on the according switch types and can be taken from the according datasheet or the user manual.

EFE...IA...

For mechanical gold contact switches or other simple apparatus the following values shall never be exceeded:

Ui = 30 V ; li = 15 mA ; Pi = 35 mW

The following values for the electrical fed through circuits shall never be exceeded:

IIC: Ui = 28 V, li = 200 mA

IIB: Ui = 32 V, li = 450 mA

EFX...EIA... The electrical data depends on the according switch types and can be taken from the according datasheet or the user manual.

EFE...EIA...

For mechanical gold contact switches or other simple apparatus the following values shall never be exceeded:

Ui = 30 V ; li = 15 mA ; Pi = 35 mW

Electrical fed through circuits:

minimum cross section size 0.5 mm<sup>2</sup>, maximum current 6 A

EFX...K2D... Maximum allowed internally dissipated power: 1 W



**EU - Type Examination Certificate EPS 16 ATEX 1 012 X**

**Revision 2**

(16) Reference number: 16TH0022

(17) Special conditions for safe use:

Maximum ambient temperature range:

EFX...ED...	T6/T80°C: -55°C/-25°C to +40°C
EFX...EIA...	T5/T95°C: -55°C/-25°C to +60°C
EFE...ED...	T4/T135°C: -55°C/-25°C to +75°C
EFE...EIA...	

EFX...IA...	Mechanical gold contact switches:
EFE...IA...	T6/T80°C: -55°C/-25°C to +70°C
	T5/T95°C: -55°C/-25°C to +80°C
	T4/T135°C: -55°C/-25°C to +100°C

Certified switches:

Depends on the respective switch type. See user manual and type plate.

EFX...K2D...	T80°C: -55°C/-25°C to +40°C
EFE...K2D...	T95°C: -55°C/-25°C to +60°C
	T135°C: -55°C/-25°C to +75°C

For the limit switch box type EFX...IA... / EFE...IA... alternative to the cable glands other, accordingly suited connectors for example M12-connector or plug connectors may be attached. These fasteners shall comply with the separation distances according to Table 5 of EN 60079-11. Unused connectors shall be covered with a dustproof cap.

The viewing glass type 2D, 3D and 3D1 is only allowed to be used to a minimum ambient temperature of -25°C.

(18) Essential health and safety requirements:

Met by compliance with standards.

Certification department of explosion protection

Hamburg, 2021-02-22



H. Schaffer